



Carbon filtration replacement

- Remove access panel from front face of the door (remove 4 screws).



- Remove carbon trays from the carbon unit use gloves also wipe and clean inside the carbon unit (Note carbon trays are also refillable / reusable).
- Slide new carbon trays in V formation (make sure formation is correct).



- Secure access panel to the face of the carbon (screw 4 screws).
- Carbon Unit is now operational.